

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
			J	1	2
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 02-Aug-2004	4. REQUISITION/PURCHASE REQ. NO. W38XGR-4037-6293		5. PROJECT NO.(If applicable) W912EQ-04-B-0017	
6. ISSUED BY US ARMY ENGINEER DISTRICT, MEMPHIS 167 N MAIN STREET B202 MEMPHIS TN 38103-1894	CODE W912EQ	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. W912EQ-04-B-0017	
			X	9B. DATED (SEE ITEM 11) 02-Jul-2004	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE		11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS		
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended.					
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) This solicitation for DD17 Fuel Oil System Replacement scheduled to open 03 August 2004 at 2:30 p.m. is amended as follows:  1. Section 00010, Page 1, SF 1442, Paragraph 13a: The hour and date for opening of bids are rescheduled to be opened on 10 August 2004 at 2:30 p.m.  Continued on Page 2					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		02-Aug-2004	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**The following items are applicable to this modification:**

## SECTION SF30 - BLOCK 14 CONTINUATION PAGE

AMENDMENT #0001

2. **Section 00800, Page 141, SP 23 Hours of Work:** This Special Contract Requirement is deleted in its entirety.
3. **Section 00800, Page 142, SP 30 Flood Emergency:** The contractor needs to be aware of this Special Contract Requirement which requires that the contractor maintain connections between the pumping station and fuel tank(s) at all times.
4. **Drawings 2 and 3:** Add the following note to both drawings: “The two manholes shown between the fuel tanks and the pump station inlet channel are to a grease and oil separator. The lines to the grease and oil separator shall be capped and the grease and oil separator left in place.”
5. **Drawing 5, Note 1 is revised to read as follows:** “The Contractor shall provide a minimum of 10,000 gallons temporary fuel tank(s). At least one temporary tank shall be located above EL. 244’ and be capable of being refilled. The Contractor shall transfer fuel from the existing fuel tanks to the temporary tank(s) and maintain connections between the pumping station and fuel supply at all times. In the event that additional fuel is needed to supply the pumping station during construction, the Government shall purchase/supply the additional fuel.”
6. **Drawing 5, Note 2 is revised to read as follows:** “Once the new fuel tanks are installed and connected to the pump station, the Contractor shall transfer all remaining fuel from the temporary and existing tanks to the new tanks. The Contractor shall clean the existing tanks in accordance with the specifications PARA. 3.4, PAGE 02050-3 prior to disposal.”
7. **Drawing 5:** The dimension from the Baseline to the left upper corner of existing concrete is revised from 26’ – 5<sup>5/8</sup>” to 126’ – 5<sup>5/8</sup>”.